



ebv building 3 test report and part b
Ken Herstowski to: O'Brien, Timothy
Cc: Edwin Buckner

08/02/2012 02:02 PM

History: This message has been forwarded.

very briefly, i see the following as major items that have not been provided:

Building 3 Test Report

1. Does not describe how waste feed rate data is obtained, calculated and recorded.
2. Does not include powdered activated carbon feed parameter data.
3. Does not describe how powdered activated carbon feed rate data is obtained, calculated and recorded.
4. Does not document sodium bicarbonate supplier and specifications.
5. Does not document powdered activated carbon supplier and specifications.
6. Does not describe and document how steady state conditions were established for testing.
7. Does not include scrubber and quench vessel liquid level parameter data.
8. Does not demonstrate compliance with particulate standard with additional feed of powdered activated carbon.
9. Does not include hg, lvm and svm feed rate limits and compliance methodology.

Part B Application

1. Does not include calibration ranges for all continuous monitoring system equipment.
2. Does not include PLC/ID# tags for all continuous monitoring system items and parameters.
3. Does not include documentation of manufacturer's specifications for opl's based on ms.
4. Does not include Subpart X units operation and maintenance plans.
5. Does not include Subpart X units startup, shutdown and malfunction plans.
6. Does not include Subpart X units operator training program plans.
7. Inappropriately includes language classifying future permit modifications.

RCRA



518848